

OUTFALL RECONNAISSANCE INVENTORY / COLLECTION FIELD SHEET

OK
1254

Section 1: Background Data

Subwatershed: <u>PB</u>		Outfall ID: <u>PB-47</u>		
Date & Time: <u>5/18/08 1:33</u>		Form completed by: <u>SCS MAS</u>		
Temperature (°F): <u>45</u>		Rainfall (in.): Last 24 hours: <u>.03</u> Last 48 hours: <u>1.76</u>		
Camera: <u>Kodak</u>		Photo #: <u>100-0372 (PB-047)</u>		
DIAMETER (IN)	MATERIAL	FLOW	DESCRIPTION	LAND USE IN AREA
Diameter: <u>24</u>	☒ RCP ☐ CMP ☐ PVC ☐ HDPE ☐ Steel ☐ Corr. Plastic ☐ Other: _____	Depth: _____ in. Width: _____ in.	☒ Trickle ☐ Moderate ☐ Substantial ☐ No Flow	☐ Industrial ☐ Urban Residential ☐ Suburban Residential ☐ Commercial ☐ Open Space ☐ Institutional Other: _____

Notes (e.g., Access to outfall, distance and bearing if necessary, unable to locate, etc):

Into one of the 3 culvert pipes
pipe end
from CB

BTR 9/3/08 9:16am 0" rain 48 hrs

INDICATOR	CHECK if Present	DESCRIPTION	RELATIVE SEVERITY INDEX (1-3)		
Odor	☐	☐ Sewage ☐ Rancid/sour ☐ Petroleum/gas ☐ Sulfide ☐ Other: _____	☐ 1 - Faint	☐ 2 - Easily detected	☐ 3 - Noticeable from a distance
Color	☐	☐ Clear ☐ Brown ☐ Gray ☐ Yellow ☐ Green ☐ Orange ☐ Red ☐ Other: _____	☐ 1 - Faint colors in sample bottle	☐ 2 - Clearly visible in sample bottle	☐ 3 - Clearly visible in outfall flow
Turbidity	☐	See severity	☐ 1 - Slight cloudiness	☐ 2 - Cloudy	☐ 3 - Opaque
Floatables - Does Not Include Trash!!	☐	☐ Sewage (Toilet Paper, etc.) ☐ Suds ☐ Petroleum (oil sheen) ☐ Other: _____	☐ 1 - Few/slight; origin not obvious	☐ 2 - Some; indications of origin (e.g., possible suds or oil sheen)	☐ 3 - Some; origin clear (e.g., obvious oil sheen, suds, or floating sanitary materials)

- Resident @ 58 Spright Arden expressed concern w/ issues of water backing up into basements, few years back town took out 2nd catchbasin and since then issues

INDICATOR	CHECK if Present	DESCRIPTION	COMMENTS
Outfall Damage	☐	☐ Spalling, Cracking or Chipping ☐ Peeling Paint ☐ Corrosion	
Deposits/Stains	☐	☐ Oily ☐ Flow Line ☐ Paint ☐ Other: _____	
Abnormal Vegetation	☐	☐ Excessive ☐ Inhibited	
Poor pool quality	☐	☐ Odors ☐ Colors ☐ Floatables ☐ Oil Sheen ☐ Suds ☐ Excessive Algae ☐ Other: _____	
Pipe benthic growth	☐	☐ Brown ☐ Orange ☐ Green ☐ Other: _____	

→ PB-47 CB has stagnant water but brook is moving, piping or other sediment could be clogged and causing back up; Outfall clogged